



TC-5389

ELECTRICAL RESEARCH AND DEVELOPMENT ASSOCIATION

(Accredited by the National Accreditation Board for Testing and Calibration Laboratories, Govt. of India)

ERDA Road, Makarpura Industrial Estate, Vadodara-390 010, India.

EPABX : +91 (0265) 2642942, 2642964, 2642377, 3043128 / 29 / 30 / 31 / 33

Fax : +91 (0265) 2638382


E-mail : erda@erda.org

Web : http://www.erda.org



RP-2425-027126

ULR No.:TC538924000028550F

TEST REPORT		SHEET 1 OF 7
NAME AND ADDRESS OF CUSTOMER M/s Bharat Electrosafe F-71, Site C, UPSIDA Surajpur, Gautam Budh Nagar Greater Noida U.P. 201308	REPORT No.	RP-2425-027126
	DATE OF ISSUE	10-12-2024
	CUSTOMER REF. No.	Letter & Form No. 035
	DATED	22-10-2024
	DATE OF SAMPLE RECEIPT	DATE OF TESTING
	12-11-2024	02-12-2024 to 10-12-2024
SAMPLE DESCRIPTION (As provided by customer) Insulating mat for electrical purposes Thickness: 2.5mm Class: B, Category: III, Colour: Blue, Size:1 x 4 meter (01 Roll) Brand Name: 1. BHARAT ELECTROSAFE 2. INSULATICAA	SAMPLE IDENTIFICATION ERDA SAMPLE CODE No. ERDA-00606355 Marking: BharatElectrosafe INSULATING MAT FOR ELECTRICAL PURPOSE SIZE 2.5 MM CLASS B CATEGORY 3 RATED VOLTAGE UP TO 11 KV ISI CM/L 8800129617 BATCH NO 2408025 MFG BY BHARAT ELECTROSAFE Bharat Electrosafe™ HIGH VOLTAGE INSULATING MATS IS 15652:2006 MADE IN BHARAT	
TEST DETAILS		TEST SPECIFICATION
Mentioned on SHEET 2 OF 7		Mentioned on SHEET 2 OF 7
REMARKS: (1) Sample conforms to the requirements as per test specification. (2) Photograph of sample is on SHEET 7 OF 7.		
 CHECKED BY	 (ANIL B. PATIL) APPROVED BY	
NOTE: 1. This report relates only to the particular sample received for testing in good condition at ERDA, Vadodara. 2. This report cannot be reproduced in part under any circumstances. 3. Publication of this report requires prior permission in writing from Director, ERDA. 4. This report shall not be used for any purpose such as PR brochures, propaganda, advertisement and/or legal proceedings, unless for the granted purpose. 5. Only the test asked for by the customer has been carried out. 6. Particulars of manufacturer/supplier, given in this report are based on information supplied by the customer, along with the test request/sample. ERDA does not assume any responsibility for the correctness of the information for above mentioned sample under test (SUT). ERDA will not be responsible for any changes in SUT made after the test. This test report is given as per instrument status while testing. 7. In case of any dispute, Vadodara will be the exclusive jurisdiction & shall be construed as where the cause has raised. Caution: ERDA is not responsible for the authenticity of photocopied or reproduced test reports. ERDA provides support to customers for verification of the authenticity of test reports issued by ERDA within 10 years of date of issue of report.		



TC 3728033